



Jim Doyle, Governor
Mary P. Burke, Secretary

June 3, 2004

WICK BUILDING SYSTEMS, INC.
NATHAN PERKINS
2301 E FOURTH ST
PO BOX 530
MARSHFIELD WI 54449

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: WICK BUILDING SYSTEMS, INC.
Product Name: PREFABRICATED PLUMBING SYSTEM
Model Number(s): A, A ALT, B, B ALT, C, C ALT, D, D ALT, E, F, F ALT, G, H, I, J, K, K ALT1, K ALT2, L, L ALT1, L ALT2, L ALT3, M, M ALT, N, N ALT, P AND O
Product File No: 20040247

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the additional or revised portions of the approved plans and/or specifications is enclosed. The plans and/or specifications shall be incorporated with your previous approval under product file number 20010547.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov